



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri, District: Darjeeling, Pin - 734005

Memo No.: FSR/0125186200502247

Date : 15-01-2025

From :
Divisional Fire Officer
Darjeeling Division,
West Bengal Fire & Emergency Services

To :
NOTRE DAME ACADEMY
MOUZA-DARJEELING JL NO-24,PLOT NO-157,158,166,170 TO 174 KH NO5633,P.S-SADAR,DIST-DARJEELING

Sub : Issuance of Renewal of Fire Safety Certificate for the G+2 Storied School Building under group Educational in name of NOTRE DAME ACADEMY at MOUZA-DARJEELING JL NO-24,PLOT NO-157,158,166,170 TO 174 KH NO5633,P.S-SADAR,DIST-DARJEELING. 00200502247

This is in reference to your AIN 211912406300003289 dated 06-Dec-2024 regarding Issuance of Renewal of Fire Safety Certificate for the G+2 Storied School Building under group Educational in name of NOTRE DAME ACADEMY at MOUZA-DARJEELING JL NO-24,PLOT NO-157,158,166,170 TO 174 KH NO5633,P.S-SADAR,DIST-DARJEELING..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Driveway must be free from any type of obstruction for easy movement of Fire Appliances, No Parking board will be allowing on the driveway.
2. To eliminate the risk of Fire Hazards, good housekeeping for both inside and outside of the building will



ATTESTED
Dr. Jyoti S.D.
Principal
Notre Dame Academy
Darjeeling

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300003289